

FWD-200P, FWD-200ACCLIMATE, FWH-200ROR135(A), FWH-200FIX135(A) SWIFT Wireless Detectors

General

SWIFT® wireless detectors are intelligent (addressable) detectors which provide secure, reliable communication to the Fire Alarm Control Panel (FACP) across a Class A mesh network. Wireless detectors create an opportunity for applications where it is costly (concrete walls/ceilings, buried wires), obtrusive (surface mount conduit), or possibly dangerous (asbestos) to use traditional wired devices. In addition, both wired and wireless devices can be present on the same FACP providing an integrated wired-wireless solution for increased installation potential.

The SWIFT detection line includes a photoelectric, Acclimate®, standard fixed heat, and rate-of-rise heat detectors. The photoelectric detectors transmit a digital representation of smoke density through a wireless mesh to a gateway and on to a FACP. The Acclimate detectors combine a photoelectric chamber and a 135°F (57°C) fixed temperature heat detector. Acclimate can also transmit an alarm signal due to heat per UL 521. The fixed heat detector and rate-of-rise detectors utilize sensors designed for open area protection with 50 foot spacing capability as approved by UL 521.

All sensors offer addressable code wheels and two LEDs. The LEDs are controlled by the panels. Operation modes include red, green, and amber colors with various solid or blink patterns.

The mesh network within the SWIFT system creates a child-parent relationship between the devices so that each device has two parents providing a second path for communications on every device. If one device can no longer operate for any reason, the rest of the devices can still communicate with each other, directly or through one or more intermediate devices.

The SWIFT system also engages frequency hopping to prevent system interference whether intentional or accidental.

The devices communicate across the mesh network through a gateway to the FACP. The FACP views the SWIFT wireless device and another addressable device on the system providing similar detection functions and outputs as a wired counterpart. In addition, both wired and wireless devices can be present on the same FACP to meet the needs of a given application. A SWIFT wireless system can use any combination of modules, smoke and heat detectors, pull stations, and A/V bases.

Features

- Wireless installation
- Class A mesh network
- Addressable code wheels
- Commercial applications
- UL 268 listed; ULC S530 listed Canadian heat detectors
- Frequency hopping
- Bi-directional communications

Compatible Control Panels

NOTE: Refer to panel documentation for UL/ULC compatibility.

- N16 INSPIRE™ Series (UL applications)
- NFS2-3030
- NFS2-640
- NFS-320/C
- NFS-320SYS/C
- NFW-100X (UL applications)
- NFW-50X (UL applications)



Components and Ordering Information

- **FWD-200P:** FlashScan® intelligent, wireless photo detector. Requires one B210W base for installation. Requires (4) CR-123A batteries (included). UL listed.
- **FWD-200ACCLIMATE:** FlashScan intelligent wireless Acclimate® heat and photo detector using combined heat and smoke sensor information and the ability to automatically adjust sensitivity based on ambient changes in the environment. Requires one B210W base for installation. Requires (4) CR-123A batteries (included). UL listed.
- **FWH-200ROR135(A):** FlashScan intelligent wireless rate of rise (135°F/57°C) heat detector. Requires one B210W base for installation. Requires (4) CR-123A batteries (included). Order FWH-200ROR135A for ULC applications.
- **FWH-200FIX135(A):** FlashScan intelligent wireless fixed-temperature (135°F/57°C) heat detector. Requires one B210W base for installation. Requires (4) CR-123A batteries (included). Order FWH-200FIX135A for ULC applications.
- **FWSG(A):** FlashScan Wireless SWIFT Gateway. One SWIFT Gateway is required for each wireless mesh, and supports up to 49 SWIFT detectors or modules. Connects to the SLC loop of a compatible panel using FlashScan protocol. Power may be supplied by the SLC circuit or via an optional 24VDC input. See *DN-60820* for other components available for use with the SWIFT Gateway. Order FWSGA for ULC applications.
NOTE: Use of the 24VDC input may be more convenient for service as it allows for powering down a gateway without shutting down an SLC loop.
- **B210W:** Detector base used for wireless detectors. Includes a built-in magnet so that wireless devices can establish installed and tampered states.
- **SMB500-WH:** Optional surface-mount backbox.

Physical/Operating Specifications

Height: 2.4" (61 mm) installed in B210W base

Diameter: 6.0" (152mm) installed in B210W base

Device Weight (includes 4 batteries): 9.2 oz (261 g) installed in B210W base

Operating Temperature Range: Photo: 32°F to 120°F (0°C to 49°C)

Air Velocity: 0 to 4,000 fpm (0 to 20 m/sec)

Operating Humidity Range: 10% to 93% non-condensing

Thermal Ratings: Fixed Temperature Set Point: 135°F/57°C; Rate-of-Rise Detection: 15°F/min (8.3°C/min)

Electrical Specifications

Radio Frequency Range: 902-928 MHz

BATTERY SPECIFICATIONS

Battery Type: 4 Panasonic® CR123A or 4 Duracell® DL 123A

Battery Life: 2 years

Battery Replacement: Upon BATTERY LOW or BAT LOW display and/or during annual maintenance

Agency Listings and Approvals

The file number(s) below reference the specific listings for the equipment in this document. In some cases, certain modules or applications may not be listed by certain approval agencies, or listing may be in process. Consult the factory for the latest listing status.

- **UL Listed:** S747 (Heat) & S1115 (Photo, Photo/heat)
- **ULC Listed:** S747 (Canadian heat detectors)
- **CSFM:** 7272-0028:0271, 7254-0028:0270
- **FM Approved**
- **FCC ID:** AUBWFSSD
- **IC ID:** 573X-WFSSD

Each device complies with part 15 of the FCC rules meaning operation is subject to two conditions: 1) The device may not cause harmful interference and 2) The device must accept any interference received including interference that may cause undesired operation.

Standards and Codes

The SWIFT Wireless Intelligent Detectors comply with the following UL Standards and with NFPA 72 Fire Alarm System requirements.

- UL 864
- UL 268
- ULC S530/CAN/ULC S529 (Canadian heat detectors)

NOTIFIER

12 Clintonville Road
Northford, CT 06472
203.484.7161
www.notifier.com



This document is not intended to be used for installation purposes.

We try to keep our product information up-to-date and accurate.

We cannot cover all specific applications or anticipate all requirements.

All specifications are subject to change without notice.

Acclimate® Plus, FlashScan®, NOTIFIER®, ONYX®, System Sensor®, and SWIFT® are registered trademarks of Honeywell International Inc.

Microsoft® and Windows® are registered trademarks of Microsoft Corporation. Duracell® is a registered trademark of Duracell U.S. Operations Inc. Panasonic® is a registered trademark of Panasonic Corporation.

©2022 by Honeywell International Inc. All rights reserved. Unauthorized use of this document is strictly prohibited.

Country of Origin: Mexico

